

# KEMA REPORT OF PERFORMANCE

1014-16

<b>Object</b>	A three-phase dry-type transformer		
<b>Type</b>	-	<b>Serial No.</b>	ADA2406008/001
	11/0,433 kV – 250 kVA – Dyn11– 50 Hz		
<b>Client</b>	Raychem RPG (P) Ltd., Pune, India		
<b>Manufacturer</b>	Raychem RPG (P) Ltd., Pune, India *)		
<b>Tested by</b>	KEMA Nederland B.V., Arnhem, The Netherlands		
<b>Date of tests</b>	25 January to 3 February 2016		
<b>Test specification</b>	The tests have been carried out in accordance with IEC 60076-11 (2004), subclause 27.4 (Thermal shock test for C2 Class transformers) and subclause 26.3.2 (Environmental test for Class E2 transformers).		
<b>Remarks</b>	The object has complied with the relevant requirements of the standard.		

This report applies only to the object tested. The responsibility for conformity of any object having the same type references as that tested rests with the manufacturer.

\*) as declared by the manufacturer

This report consists of 17 pages in total.

KEMA Nederland B.V.



J.P. Fonteijne  
Executive Vice President  
KEMA Laboratories



Laboratories

Arnhem, 8 March 2016

## INFORMATION SHEET

### 1 KEMA Type Test Certificate

A KEMA Type Test Certificate contains a record of a series of (type) tests carried out in accordance with a recognized standard. The equipment tested has fulfilled the requirements of this standard and the relevant ratings assigned by the manufacturer are endorsed by DNV GL. In addition, the test object's technical drawings have been verified and the condition of the test object after the tests is assessed and recorded. The Certificate contains the essential drawings and a description of the equipment tested. A KEMA Type Test Certificate signifies that the object meets all the requirements of the named subclauses of the standard. It can be identified by gold-embossed lettering on the cover and a gold seal on its front sheet.

The Certificate is applicable to the equipment tested only. DNV GL is responsible for the validity and the contents of the Certificate. The responsibility for conformity of any object having the same type references as the one tested rests with the manufacturer.

Detailed rules on types of certification are given in DNV GL's Certification procedure applicable to KEMA Laboratories.

### 2 KEMA Report of Performance

A KEMA Report of Performance is issued when an object has successfully completed and passed a subset (but not all) of test programmes in accordance with a recognized standard. In addition, the test object's technical drawings have been verified and the condition of the test object after the tests is assessed and recorded. The report is applicable to the equipment tested only. A KEMA Report of Performance signifies that the object meets the requirements of the named subclauses of the standard. It can be identified by silver-embossed lettering on the cover and a silver seal on its front sheet.

The sentence on the front page of a KEMA Report of Performance will state that the tests have been carried out in accordance with ..... The object has complied with the relevant requirements.

### 3 KEMA Test Report

A KEMA Test Report is issued in all other cases. Reasons for issuing a KEMA Test Report could be:

- Tests were performed according to the client's instructions.
- Tests were performed only partially according to the standard.
- No technical drawings were submitted for verification and/or no assessment of the condition of the test object after the tests was performed.
- The object failed one or more of the performed tests.

The KEMA Test Report can be identified by the grey-embossed lettering on the cover and grey seal on its front sheet.

In case the number of tests, the test procedure and the test parameters are based on a recognized standard and related to the ratings assigned by the manufacturer, the following sentence will appear on the front sheet. The tests have been carried out in accordance with the client's instructions. Test procedure and test parameters were based on ..... If the object does not pass the tests such behaviour will be mentioned on the front sheet. Verification of the drawings (if submitted) and assessment of the condition after the tests is only done on client's request.

When the tests, test procedure and/or test parameters are not in accordance with a recognized standard, the front sheet will state the tests have been carried out in accordance with client's instructions.

### 4 Official and uncontrolled test documents

The official test documents of DNV GL are issued in bound form. Uncontrolled copies may be provided as loose sheets or as a digital file for convenience of reproduction by the client. The copyright has to be respected at all times.

## TABLE OF CONTENTS

1	Identification of the test object .....	4
1.1	Ratings assigned by the manufacturer	4
1.2	Description of the test object	4
1.3	List of drawings	5
1.4	The tests were witnessed by	6
1.5	The tests were carried out by	6
1.6	Purpose of the test	6
1.7	Measurement uncertainty	6
2	Climatic test .....	7
2.1	Thermal shock test for C2 class transformers	7
2.2	Separate source AC withstand voltage test at 80% of test voltage	9
2.3	Induced AC withstand voltage test at 80% of test voltage	9
2.4	Partial discharge measurement	10
3	Environmental tests for Class E2 transformers .....	11
3.1	Condensation test	11
3.2	Humidity penetration test	12
3.2.1	Repetition of separate source AC withstand voltage test at 80% of test voltage	12
3.2.2	Induced AC withstand voltage test at 80% of test voltage	13
4	Photographs .....	14
5	Drawings.....	15
6	Measurement uncertainty.....	17

## 1 IDENTIFICATION OF THE TEST OBJECT

### 1.1 Ratings assigned by the manufacturer

Rated power	250 kVA
Rated primary voltage	11 kV
Rated secondary voltage	433 V
Rated primary current	13,12 A
Rated secondary current	333,34 A
Rated frequency	50 Hz

### 1.2 Description of the test object

Manufacturer	Raychem RPG (P) Ltd., Pune, India
Type	-
Designation	-
Serial number	ADA2406008/001
Year of manufacture	2015
Number of phases	3
Insulation levels	
• HV winding (LI/AC)	75 / 28
• LV winding (LI/AC)	- / 3
Tapping range	$\pm 2 \times 2,5\%$
Number of tappings	5
Impedance voltage	5%
Connection symbol	Dyn11
Type of cooling	AN
Primary winding material	copper
Secondary winding material	copper
Reference temperature	120 °C
Insulation class (HV / LV)	F / F
Climatic class	C2
Environmental class	E2

### 1.3 List of drawings

The manufacturer has guaranteed that the object submitted for tests has been manufactured in accordance with the following drawings and/or documents. KEMA Laboratories has verified that these drawings and/or documents adequately represent the object tested. The manufacturer is responsible for the correctness of these drawings and/or documents and the technical data presented.

The following drawings and/or documents have been included in this report:

Drawing no./document no.	Revision
32GA0256 R1	1
32RD0431 R1	1

## GENERAL INFORMATION

### 1.4 The tests were witnessed by

<b>Name</b>	<b>Company</b>
P. K. Mujumdar (25 to 27 January 2016)	Raychem RPG (P) Ltd., Pune, India

### 1.5 The tests were carried out by

<b>Name</b>	<b>Company</b>
S. Smeenk	KEMA Nederland B.V., Arnhem, The Netherlands

### 1.6 Purpose of the test

Purpose of the test was to verify whether the material complies with the specified requirements.

### 1.7 Measurement uncertainty

A table with measurement uncertainties is enclosed in this report. Unless otherwise stated, the measurement uncertainties of the results presented in this report are as indicated in that table.

## 2 CLIMATIC TEST

### 2.1 Thermal shock test for C2 class transformers

#### Standard and date

Standard IEC 60076-11, clause 27.4

Test date 25 January 2016

#### Environmental conditions (end of cooling period)

Ambient temperature -25 °C

Temperature of test object -25 °C

#### Characteristic test data

Test current through high voltage winding,  
three coils connected in series

$$2 \cdot I_{nom} / \sqrt{3} = 15,1 \text{ A dc}$$


Test current through low voltage winding,  
three coils connected in series

$$2 \cdot I_{nom} = 667 \text{ A dc}$$

#### Winding resistances

Winding	At -25 °C (Ω)	At 140 °C (Ω)
HV winding	6,30	11,3
LV winding	$2,48 \times 10^{-3}$	$4,42 \times 10^{-3}$

WINDING TEMPERATURES  
(coils in series)



Graph of the winding temperatures during the test.

**Requirements**

The transformer shall withstand the dielectric routine tests at 80% of the specified test voltages.  
The windings shall show no visible abnormalities such as cracks or slits.

**Result**

The object passed the test.



## 2.2 Separate source AC withstand voltage test at 80% of test voltage

### Standard and date

Standard IEC 60076-11, clause 19  
 Test date 26 January 2016

### Environmental conditions

Ambient temperature 20 °C Ambient air pressure 1001 hPa  
 Temperature of test object 20 °C Humidity 9 g/m<sup>3</sup>

Voltage applied to terminals	Earthed	Applied voltage (kV)	Frequency (Hz)	Duration (min)	Observations
1U, 1V, 1W	2U, 2V, 2W, 2N, core, frame	22,4	50	1	No particularities
2U, 2V, 2W, 2N	1U, 1V, 1W, core, frame	2,4	50	1	No particularities

### Requirement

There shall be neither flashover nor breakdown during the dielectric tests.

### Result

The object passed the test.

## 2.3 Induced AC withstand voltage test at 80% of test voltage

### Standard and date

Standard IEC 60076-11, clause 20  
 Test date 26 January 2016

### Environmental conditions

Ambient temperature 20 °C Ambient air pressure 1001 hPa  
 Temperature of test object 20 °C Humidity 9 g/m<sup>3</sup>

Voltage applied to terminals	Earthed	Applied voltage; phase-phase (kV (...x Ur))	Frequency (Hz)	Duration (min)	Observations
2U, 2V, 2W	2N, core, frame	17,6 (1,6)	100	1	No particularities

### Requirement

There shall be neither flashover nor breakdown during the dielectric tests.

### Result

The object passed the test.

## 2.4 Partial discharge measurement

### Standard and date

Standard IEC 60076-11, clause 22  
 Test date 26 January 2016

### Environmental conditions

Ambient temperature 20 °C Ambient air pressure 1001 hPa  
 Temperature of test object 20 °C Humidity 9 g/m<sup>3</sup>

### Characteristic data

Noise ≤1 pC Test frequency 100 Hz  
 Sensitivity 2 pC Calibration level 5 pC  
 Center frequency 200 Hz  
 Bandwidth 160 kHz  
 U<sub>r</sub> 11 kV

Phase	Applied voltage; phase-phase (kV (...xU <sub>r</sub> ))	Phase earthed	Duration (s)	Partial discharge level (pC)	Inception		Extinction	
					(kV)	(pC)	(kV)	(pC)
1U-1V-1W	17,6 (1,6)	None	60	Not detectable	-	-	-	-
1U	14,3 (1,3)	None	180	Not detectable	-	-	-	-
1V	14,3 (1,3)	None	180	Not detectable	-	-	-	-
1W	14,3 (1,3)	None	180	Not detectable	-	-	-	-

### Requirement

The maximum level of partial discharges shall be 10 pC.

### Result

The object passed the test.

### 3 ENVIRONMENTAL TESTS FOR CLASS E2 TRANSFORMERS

#### 3.1 Condensation test

##### Standard and date

Standard IEC 60076-11, clause 26.3.2

Test date 27 January 2016

##### Environmental conditions

Ambient temperature Approx. 18 °C Ambient air pressure 1011 hPa

##### Characteristic test data

Temperature of test object 5..18 °C  
 Humidity (relative) > 93 %  
 Dimensions of test room 5x5x3 m  
 Conductivity of atomized water 1,1 S/m  
 Duration of exposure 6 h

After 6 hours of condensation, the test object was subjected to the induced voltage test as described below.

##### Transformers to be used in a system with solidly earthed neutral or via low impedance

Voltage applied to terminals	Earthed	Applied voltage; phase-phase on LV windings (V (...xU <sub>r</sub> ))	Frequency (Hz)	Duration (min)	Observations
2U, 2V, 2W	2N, core, frame	476 (1,1)	50	15	A small amount of smoke was observed located near one of the lower support blocks of the U-coil

##### Requirements

- There shall be no flashover during the voltage application.
- Visual inspection shall not show any serious tracking.

##### Result

The object passed the test.

## 3.2 Humidity penetration test

### Standard and date

Standard IEC 60076-11, clause 26.3.2  
 Test dates 28 January to 3 February 2016

### Characteristic test data

Temperature of test object 50 °C  
 Humidity (relative) 90 %  
 Dimensions of test room 3,4x5,0x4,0 m  
 Duration of test 144 h

### 3.2.1 Repetition of separate source AC withstand voltage test at 80% of test voltage

#### Standard and date

Standard IEC 60076-11, clause 19  
 Test date 3 February 2016

#### Environmental conditions

Ambient temperature 21 °C Ambient air pressure 1013 hPa  
 Temperature of test object 30-50 °C Humidity 7 g/m<sup>3</sup>

Voltage applied to terminals	Earthed	Applied voltage (kV)	Frequency (Hz)	Duration (min)	Observations
1U, 1V, 1W	2U, 2V, 2N, core, frame	22,4	50	1	-
2U, 2V, 2W, 2N	1U, 1V, 1W, core, frame	2,4	50	1	-

#### Requirement

There shall be neither flashover nor breakdown during the dielectric tests.

#### Result

The object passed the test.

### 3.2.2 Induced AC withstand voltage test at 80% of test voltage

**Standard and date**

Standard IEC 60076-11, clause 20

Test date 3 February 2016

**Environmental conditions**

Ambient temperature 21 °C

Ambient air pressure 1013 hPa

Temperature of test object 30-50 °C

Humidity 7 g/m<sup>3</sup>

Voltage applied to terminals	Earthed	Applied voltage; phase-phase (kV (...x Ur))	Frequency (Hz)	Duration (min)	Observations
2U, 2V, 2W	2N, core, frame	17,6 (1,6)	100	1	-

**Requirement**

There shall be neither flashover nor breakdown during the dielectric tests.

**Result**

The object passed the test.

## 4 PHOTOGRAPHS




Transformer in the test bay for the condensation test.



Transformer in the climatic chamber and prepared for the thermal shock test.


# 5 DRAWINGS



SCALE - HTS	APPROVED	DWG NO	SHEET NO. - 1 OF 1
CSJ 10.10.12	PKM 10.10.12	SBSJA05SD BI	
CUSTOMER NAME	BATCH NO	TITLE	
ADJAG08008		GENERAL ASSEMBLY DRAWING	
SIGNATURE	DATE	FORM IT.	SCALE & DATE
REVISIONS	DATE	BY	REASON
DRAWING No.		DRAWING No.	
THE SUPERVISOR		THIS IS SUPERSEDED BY	
THIS IS SUPERSEDED BY			

**Raychem RPG Limited, Pune - 410501**


FORM No. RPG 04 003



## Raychem *RPG* (P) LTD.

DRY TYPE CAST RESIN TRANSFORMER -CRT

CUSTOMER	M/s.
ORDER/CONTRACT No	
YEAR OF MANUFACTURE	2015
TRANSFORMER SRL No	ADA2406008
KVA	250
VOLTS AT NO LOAD	HV 11000 LV 433
AMPERES	HV 13.12 LV 333.34
PHASES	3
FREQUENCY	50 Hz
INSULATION CLASS	F
MAX AMB TEMP	50°C
MAX TEMP RISE IN WDG	90°C ABOVE AMB
WINDING MATERIAL	COPPER.
INSULATION LEVEL	LI 75 AC 2B / AC 3
VECTOR GROUP	Dyn11
TYPE OF COOLING	AN
REF. STD	IEC:60076-11,IS:11171
CORE-COIL ASSY Wt	kg 1150 Kg
TOTAL Wt	Kg 1250 Kg



POSN NO	HV LEAD CONNECTION	HV VOLTS	HV AMPS	LV VOLTS
1	6-5	11550	12.50	433
2	5-7	11275	12.80	
3	7-4	11000	13.12	
4	4-8	10725	13.46	
5	8-3	10450	13.81	

**CAUTION:-DE-ENERGISE TRANSFORMER BEFORE CHANGING THE TAP LINKS.**

MFG AT: 426/2B, CHAKAN-TALEGAON ROAD, MAHALUNGE,PUNE-410501(INDIA)  
Website:www.raychemrpg.com


**NOTE:-**

1. MATL-STAINLESS STEEL(304) 0.71 THK.
2. PLATE TO BE SUITABLE FOR OUTDOOR USE & IN TROPICAL CONDITIONS.
3. FINISH WITH EPILUX 4 ENAMEL CLEAR LACQUER 20 MICRONS.
4. PLATE TO BE ANODISED ON BOTH SIDES TO GRADE AC 2 OF IS-1868
5. ALL LETTERS AND FIGURES ARE BLACK ON BRIGHT BACK GROUND.
6. TESTED IMPEDENCE VOLTAGE WILL BE PUNCHED ON R & D PLATE.
7. NOTE FOR "CAUTION:-"ARE IN RED ON BRIGHT BACK GROUND.
8. MONOGRAM COLOR SHADE AS PER RAYCHEM RPG LOGO COLOR CODE.
9. 4 FIXING HOLES DIA 4mm.

REV.	ESD0076-11 REFERENCE A0003.
ZONE	
ALL INFORMATION CONTAINED IN THIS DOCUMENT IS CONFIDENTIAL AND THE PROPERTY OF Raychem RPG Limited Pune - 410501. IT IS TO BE KEPT STRICTLY CONFIDENTIAL AND NOT TO BE LOANED, REPRODUCED OR DISCLOSED TO ANY OTHER PERSONS WITHOUT THE EXPRESS PERMISSION OF THE COMPANY.	
THIS IS SUPERSEDED BY	

INSTR. RECORD	
DRAWING No.	
DATE	28.02.16
DATE	
DATE	

CUSTOMER NAME	
BATCH NO	ADA2406008
TITLE	BEATING & DIECASTING PLATE
SIZE - HRS	
APPROVED	
DRW NO	
SHEET NO. - 1 OF 1	



**Raychem *RPG* (P) LTD. Pune - 410501**

FORM No. RRG 04 003



## 6 MEASUREMENT UNCERTAINTY

The measurement uncertainties in the results presented are as specified below unless otherwise indicated.

Measurement	Measurement uncertainty
dielectric tests and impulse current tests:	
peak value	≤ 3%
time parameters	≤ 10%
capacitance measurement	0,3%
tan δ measurement	± 0,5% ± 5 × 10 <sup>-5</sup>
partial discharge measurement:	
< 10 pC	2 pC
10 to 100 pC	5 pC
> 100 pC	20%
measurement of impedance	≤ 1%
AC-resistance measurement	
measurement of losses	≤ 1%
measurement of insulation resistance	≤ 10%
measurement of DC resistance:	
1 to 5 μΩ	1%
5 to 10 μΩ	0,5%
10 to 200 μΩ	0,2%
radio interference test	2 dB
calibration of current transformers	2,2 × 10 <sup>-4</sup> I <sub>i</sub> /I <sub>u</sub> and 290 μrad
calibration of voltage transformers	1,6 × 10 <sup>-4</sup> U <sub>i</sub> /U <sub>u</sub> and μrad
measurement of conductivity	5%
measurement of temperature:	
-50 to -40 °C	3 K
-40 to 125 °C	2 K
125 to 150 °C	3 K
tensile test	1%
sound level measurement	type 1 meter as per IEC 60651 and ANSI S1,4,1971
measurement of voltage ratio	0,1%